

ADDENDUM No. 1

February 18, 2014

ADDENDUM TO: Convert 2 CP Axial Fans to VSD
BID NUMBER: 13-06
BID DUE DATE: Thursday, February 20, 2014 at 10:00am

TO BIDDER: This addendum is an integral part of the Bid file under consideration by you as a bidder in connection with the subject matter identified above. For the purpose of clarification the following additions, changes, modifications and replacements noted below have been made to the Bid and have been made to the Bid file which bears the above title.

Bid Proposals submitted shall conform to these additions and modifications noted herein and including all issued addendums.

SEE ATTACHED CLARIFICATIONS
PAGE 1

Note: To qualify your proposal, of which this addendum becomes a part, this form must be completed and returned to this office with the proposal.

Date: _____

Authorized Signature of Company Rep.

Printed Name of Company Rep.

Company: _____

Address: _____

Telephone: _____

Contact's Email: _____

ADDENDUM ONE to

**TAMPA SPORTS AUTHORITY
BID #13-06**

**CONVERT 2 CP AXIAL FANS TO VSD
AT
RAYMOND JAMES STADIUM
4201 N. DALE MABRY HIGHWAY
TAMPA, FL 33607
February 17, 2014**

The following clarifications shall be made:

1. Connection to controls system shall be performed by a qualified Metasys dealer/technician.
2. Vanes shall be left in place locked open, at 100% open position.
3. Location of VSD can be mounted on the adjacent wall, however it must be located such that it doesn't not obstruct access to any other equipment, switches, etc.
4. Return air compressors to owner.
5. Remove copper lines leading from the compressor to the unit and seal holes to provide an airtight seal that will not allow leakage.
6. Metasys programming shall be included in the scope of work and will be directed to the graphics on the AHU.
7. The new VSD shall be connected to the current Fire Alarm System. Contact shall be Jim Hampton at Simplex Grinnell, 813-299-0317.
8. On the load side, the wiring shall be continuous.
9. Wiring for controls shall be placed inside conduct.

END OF ADDENDUM ONE